MORRIS FORMAN WWTP ODOR SURVEY

Job # 266-04 Survey: No. 4 Observer: BK Date: 10/30/01

STATION	TIME	H_2S (ppb)	INTENSITY (1-5)	ODOR DESCRIPTION	TEMP. (^oF)	WIND DIRECTION	WIND SPEED (mph)	OBSERVER/COMMENTS
12	4:12 PM	10	1	Grass	70	-	0	
13	4:15 PM	10	2	Chlorine	70	-	0	
14	4:18 PM	8.5	3	Sludge	70	-	0	
15	4:21 PM	9	3	Sludge	70	-	0	
16	3:58 PM	9.5	1	Grass	70	-	0	
17	4:02 PM	76.3	4	Sludge	70	-	0	
18	4:05 PM	26.5	1	Act. Sludge	70	-	0	

Summary: Neither scurbber running.
South Biotower out of service.
OIS system operating in DAFT room. Started on 10/26/01.
Odor levels very low today.